

Schedule - J
Format or invoice

 To, SSE (M) Electrical, Kalyan

 Date of JMR- 30/4/2019

 Meter No.- X0658714

 Date of Issue- 30/4/2019

Meter Reading		Electricity (kWh)	Tariff (Rs/kWh)	Tax (Rs)	Total Amount Payable (Rs)
Start Date	End Date				
2-11 30/4/2019					

Date of JMR-

 Meter No.- NA

Date of Issue-

Meter Reading		Electricity (kWh)	Tariff (Rs/kWh)	Tax (Rs)	Total Amount Payable (Rs)
Start Date	End Date				

Payment shall be made before- Date:

For Railways


 Authorized Signatory

 Name: Shi Satheshan C.S.

 Designation: SSE (E/M) Kalyan.

For Azure Power Rooftop Four

Pvt. Ltd


 Authorized Signatory

 Name: Dinesh Singh

 Designation: Engineer


Synchronisation Certificate

To Whomsoever this may concern

Subject: Satisfactory Synchronisation Certificate for Solar Plant.

We, Azure Power Rooftop Four Pvt Ltd (having our registered office at 3rd Floor, Asset 301-304 and 307, WorldMark 3, Aerocity, New Delhi - 110037), hereby certify that the installation and commissioning of the Grid Connected Rooftop solar power plant sanctioned vide Letter Of Award (LOA) No: REMCL/CO/IR/Solar 67 MW/Azure dt.13.10.2017 in accordance with REMCL RfQ No: REMCL/Rly/Roof Top/2017/1 dt.13.04.2017 with details as below has been satisfactorily completed in an organized manner on the Date 27/4/2019 and that to the best of our knowledge there are no problems or complaints regarding the installation and operation of the plant.

Project Location	Central Railway School, Kalyan
Project Capacity	50 kWp
Date of Installation	27/4/2019

Plant Synchronized and commissioned at 30/4/2019 AM/PM on 3:28 with the Grid.
Following are the meter serial number and corresponding CT ratio:

METERING PANEL Sr. No.: 1603/MP/50KW-25

DESCRIPTION	MAIN METER	CHECK METER
Energy Meter Sr.No.	X0658714	X0658713
CT Ratio	75/5	75/5

For Railways


Authorized Signatory

Name: Sri Satheeshan C.S.

Designation: SSE (E/M) Kalyan.

For Azure Power Rooftop Four

Pvt.Ltd


Authorized Signatory

Name: Devesh Singh

Designation: Engineer



The unit is completely connected and only checked with
ad, but Net metering from MSEDCCL is not connected so
the unit is not using on load, till net metering process w
omplete from firm.